A0 - Do not scale

Drawing Notes:

1. Refrigerant pipe, tray and VRV system installation shall follow Manufacturer requirement and recommendation

2. Full smoke extract system including but not limited to fans, ducts. Motorized smoke dampers, manually opened egress doors etc are to be installed in phase 1.

3. All external MEP plant and services distribution shall be supported on a non penetrative support system such as Bigfoot (or other equal and approved). All other MEP plant and services distribution throughout the project shall be supported on/by a suitably designed services support structure. The design and installation of this system shall be the responsibility of the contractor and technical proposals should be issued for approval. Final design of the support system located at roof level shall be co-ordinated with roof construction details to ensure full compliance of warranties and waterproofing details. The contractor shall ensure support system installation is in full compliance with seismic requirements applicable to the sites location as stipulated by local code, regional regulations and NTC2018 as per DM 17/01/2018, par.7.2.3.



1 Ground Floor - Drainage Layout - Customer Office
1 : 100



2 Ground Floor - Water Supply Layout - Customer Office
1 : 100



3 Ground Floor - AC & Refrigerant Layout - Customer Office
1 : 100



4 Ground Floor - Ventilation and Smoke Extract Layout - Customer Office
1 : 100



5 Ground Floor - Fire Protection Layout @ Low Level - Customer Office
1 : 100



6 Ground Floor - Fire Protection Layout @ High Level - Customer Office
1 : 100

Drawing Development

This drawing has been developed from the following Design Information:

Architectural Model:
MXP-MAE-ZZ-ZZ-M3-A-00001
Received: 28/04/24

Structural Model:
MXP-MAE-ZZ-ZZ-M3-S-00001
Received: 11/09/23

Civil Model:
MXP-MAE-ZZ-ZZ-M3-C-00001
Received: 27/07/23

General Notes

1. This drawing has been checked in accordance with Black & White Engineering (B&W) QA checking procedures.
2. Do not scale from this drawing. All dimensions indicated are in millimeters unless otherwise stated. Verify all critical lists of measurements on site.
3. All grid lines and equipment dimensions are typical. The Contractor should show actual, approved plant and equipment sizes.
4. This drawing is to be read in conjunction with all relevant B&W MEP specifications, schedules and standard key to symbols sheet.
5. Any discrepancies between the drawings and other documents should be brought to the attention of the engineer.
6. This drawing is not an installation drawing. It is the Contractors responsibility to make final measurements on installation shop drawings.
7. Final ceiling coordination subject to interior design package.
8. Contractor to coordinate final distribution routes with available sleeves and openings in beams / structure.
9. The contents of this drawing shall be read in conjunction with the current revisions of other relevant Architectural, Structural, Mechanical and Electrical drawings and all relevant sections of the specifications.

1000 0 1000 2000 3000 4000
SCALE: 1:100

Key Plan



Legend: Combined Mechanical Services

- VRV Indoor Unit (VIU)
- Ceiling cassette unit
- Refrigerant containment comprising of class 4 galvanised steel tray containment installed at high level within ceiling void
- Access zone
- Supply Air Terminal
- Return Air Terminal
- Extract Air Terminal
- Volume Control Damper (VCD)
- Bellmouth c/w mesh screen
- Motorised Smoke Control Dampers (MSCD)
- Manually Opened Egress Door
- Upright Sprinkler Head
- Pendant Sprinkler Head
- Concealed Sprinkler Head
- Air Vent
- Motorized Fire Damper (MFD)
- Condensate Pipe (CDP)
- Waste Pipe (WP)
- Vent Pipe (VP)
- Smoke Make-up Air Duct (SMAD)
- Smoke Extract Duct (SED)
- Fresh Air Duct (FAD)
- Exhaust Air Duct (EAD)
- Fire main pipe
- Sprinkler pipe
- Drain pipe
- Thermostat

Mechanical Equipment Asset Nomenclature:

XXX-XX-XX-XX
- Sequential Number (Starting from 01)
- Equipment Reference: ie. ACU, GEN, SEF, VIU
- Phase of Installation: 01 - Phase 1, 02 - Phase 2, 03 - Phase 3, 04 - Phase 4
- Project Code: MXP-I

Abbreviation / Annotations:

AAV	=	Air Admittance Valve
F/A	=	From Above
T/A	=	To Above
F/B	=	From Below
T/B	=	To Below
L/L	=	Low Level
H/L	=	High Level
SVP	=	Soil Vent Pipe
RPR	=	Refrigerant Pipe Riser
RPT	=	Refrigerant Pipe Tray
DTLL	=	Down To Low Level
l/s	=	Liters per second
SEF	=	Smoke Extract Fan
SED	=	Smoke Extract Duct
MSCD	=	Motorized Smoke Control Damper
FR	=	Fire Rated
SPR	=	Sprinkler Pipe

Rev	Details	By / Chkd / App	Date
P07	IFC - Design Bulletin No.3	OSV / RS / MB	20/09/2024
P06	Issued For Construction	OSV / RS / MB	21/07/2023
P05	Issued For Compass Review	OSV / RS / MB	23/06/2023
P04	Issued For QA/QC	OSV / RS / MB	16/06/2023
P03	Issued For Construction	OSV / AZS / JD	17/02/2023
P02	Issued For Compass Review	OSV / RS / MB	01/02/2023
P01	Issued For QA/QC	OSV / RS / MB	27/01/2023

Client: COMPASS Datacenters

Architectural / Civil / Structural: MAESTRALE

Lead Consultant / MEP Designer: Black & White Engineering
Office No. 1001
Marina Plaza
Dubai marina
PO Box 23783
Tel: +971 4 360 2228
www.bw-engineering.com

Project Title: MXP I-I

Drawing Title: Mechanical Services
Support Building
Customer Office & Storage
Combined Mechanical Services Layout

Project Status: **ISSUED FOR CONSTRUCTION**

Discipline	Status Code
Mechanical	S5

Project Number	Scale @ A0	Revision
P10424	1 : 100	P07

Drawing Number: MX101

Autodesk Docs://P10424_MXP/MXP-BW-ZZ-ZZ-M3-A-00001.rvt
20/05/2025 22:35
Ali Amer, Ayub